



Solicitation Amendment No. 001

To:	Date:
Prospective Proposers:	November 27, 2012
Project Title:	Project No.:
Switchgear and Duct Bank Infrastructure for Central Campus	13-06

The solicitation for Switchgear and Duct Bank Infrastructure for Central Campus is hereby amended as set forth herein.

Drawing SE-1.0 (See Electrical Plans 1)

1. Relocated the existing transformer serving J B Whiteley building and also rerouted feeder to the existing transformer for the J B Whiteley building.
2. Revised the number of conduits to the new San Jacinto building transformer and added provisions to temporarily feed the San Jacinto building if the new primary service is not available in time refer to drawing notes 11, 12, 13 and 23.

Drawing SE-1.1 (See Electrical Plans 2)

1. Relocated existing transformer and corrected routing of existing feeder to the JB Whiteley building.
2. Adjusted the new duct band along Holman Street out of the tree roots.

Specifications (See Infrastructure Specifications)

Revise name of specification section 26 13 02 AND TABLE OF CONTENT from METAL ENCLOSED SWITCHGEAR MEDIUM VOLTAGE 15 KV TO METAL CLAD SWITCHGEAR MEDIUM VOLTAGE 15 KV.

Acknowledgement of Amendment No. 001 by:	Date:
Company Name (Bidder/Offerer):	
Signed by:	
Name (Type or Print):	Title:



Purchasing Dept.
3100 Main St.
Houston, TX 77002

ATTACHMENT NO. 2
(Revised: 11/27/12)
SCHEDULE OF ITEMS AND PRICES
FOR
SWITCHGEAR AND DUCT BANK INFRASTRUCTURE CENTRAL CAMPUS
PROJECT # 13-06

The Proposer/Contractor shall furnish all necessary resources and services necessary and required to provide Switchgear & Duct Bank Infrastructure, in accordance with the Project Manual and Construction Drawings hereby incorporated and made a part of this RFCSP and the general terms and conditions of the sample contract for the prices listed below. Please provide a **Project Total Proposed Price** reflecting all project costs to successfully complete the Switchgear & Duct Bank Infrastructure. Work requirements will be specified in individual purchase orders issued by Houston Community College. **Please submit this form (Part I and II) in separate sealed envelope and label it "Price Proposal".**

ITEM	DESCRIPTION OF WORK/ITEMS	Proposed Price
001	REMOVAL OF EXISTING PAVEMENTS, CURBS, AND STRUCTURES	\$
002	EARTHWORK: CLEARING, EXCAVATION, FILL, AND GRADING	\$
003	VEHICULAR PAVEMENT : ASPHALTIC (REPAIR OVER TRENCH)	\$
004	WALKWAYS – CURBS AND SIDEWALKS (REPAIR OVER TRENCH)	\$
005	ELECTRICAL	
	005A) CNP PPRIMARY SERVICE & METERING CABINET	\$
	005B) PRIMARY FEEDER FROM METERING CABINET TO SWITCHGEAR	\$
	005C) CONCRETE PADS	\$
	005D) SWITCHGEAR	\$
	005E) DUCT BANK & 5 MANHOLES	\$
	005F) PRIMARY FEEDERS	\$
006	TREE PROTECTION: TREE & ROOT TREATMENT & PROTECTION (Urban Forester to be hired by HCC. All Tree Protection to be provided under General Contractor). Tree protection specifications and details will be added via Amendment #002.	\$
007	OTHER COSTS: ITEMIZE AND DESCRIBE ON SEPARATE PAGE	\$
008	OVERHEAD & PROFIT	\$
009	OWNERS CONTINGENCY	\$ 120,000.00

Total Proposed Price (Items 001-009): \$ _____

Note: Total proposed price must equal the total line item cost for items 001-009

Proposer's Maximum Project Duration in Calendar Days: _____



Purchasing Dept.
3100 Main St.
Houston, TX 77002

Schedule – Draft Schedule is being added, however, proposer(s) will be responsible for providing a schedule to meet the project duration as proposed.

Except as provided herein, all terms and conditions of the solicitation, remain unchanged and in full force and effect.



Solicitation Amendment No. 002

To:	Date:
Prospective Proposers:	November 30, 2012
Project Title:	Project No.:
Switchgear and Duct Bank Infrastructure for Central Campus	13-06

The solicitation for Switchgear and Duct Bank Infrastructure for Central Campus is hereby amended as set forth herein.

In accordance with the referenced solicitation, in particular, Instruction to Proposers, Section 3.c and 3.d, proposers are hereby requested to provide the following:

- a. Firm's Financial Status – Provide evidence of the firm's financial stability including but not limited to, any one or more of the following: the firm's audited financial statement for the last two (2) years; a statement from at least one financial institution with validation of at least six (6) months working capital; recent annual reports or equivalent information and your short and long-term credit rating; a letter from the company's CPA attesting to the company's financial stability.
- b. Bonding Capability – Provide a letter from a surety or insurance company, stating your firm's total bonding capacity and your firm's current available bonding limits. This letter is to serve as a certified statement of bonding capacity, and is not a request for a bond of any kind. Please know a letter indicating "unlimited" bonding capability is not acceptable.

Except as provided herein, all terms and conditions of the solicitation, remain unchanged and in full force and effect.

Acknowledgement of Amendment No. 002 by:	Date:
Company Name (Bidder/Offerer):	
Signed by:	
Name (Type or Print):	Title:



Purchasing Dept.
3100 Main St.
Houston, TX 77002



Solicitation Amendment No. 003

To:	Date:
Prospective Bidder/Offeror:	January 03, 2013
Project Title:	Project No.:
Switchgear and Duct Bank Infrastructure Central Campus	13-06
Description of Solicitation Amendment: The solicitation Switchgear and Duct Bank Infrastructure Central Campus (#13-06) has been amended as follows:	
I. The solicitation for Switchgear and Duct Bank Infrastructure Central Campus (Project 13-06) is hereby cancelled in its entirety.	
Acknowledgement of Amendment No. 003 by:	Date:
Company Name (Bidder/Offerer):	
Signed by:	
Name (Type or Print):	Title:



Procurement Operations
3100 Main St.
Houston, TX 77002